

## OUTSIDE AIR CALCULATION

**ENTRY #01:** 1,040 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.06 CFM/SQ. FT. x 1040 SQ. FT. = 63 CFM  
 5 CFM/PERSON x 11 PEOPLE = 55 CFM  
 118 CFM

ENTRY #01 IS SERVED BY RTU-13 WITH 200 CFM OUTSIDE AIR PROVIDED

**CLASSROOM #100:** 527 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.18 CFM/SQ. FT. x 527 SQ. FT. = 95 CFM  
 10 CFM/PERSON x 13 PEOPLE = 130 CFM  
 225 CFM

CLASSROOM #100 IS SERVED BY RTU-1 WITH 240 CFM OUTSIDE AIR PROVIDED

**CLASSROOM #150:** 527 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.18 CFM/SQ. FT. x 527 SQ. FT. = 95 CFM  
 10 CFM/PERSON x 13 PEOPLE = 130 CFM  
 225 CFM

CLASSROOM #150 IS SERVED BY RTU-2 WITH 240 CFM OUTSIDE AIR PROVIDED

**CLASSROOM #200:** 557 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.18 CFM/SQ. FT. x 557 SQ. FT. = 101 CFM  
 10 CFM/PERSON x 14 PEOPLE = 140 CFM  
 241 CFM

CLASSROOM #200 IS SERVED BY RTU-3 WITH 240 CFM OUTSIDE AIR PROVIDED

**CLASSROOM #250:** 870 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.18 CFM/SQ. FT. x 870 SQ. FT. = 157 CFM  
 10 CFM/PERSON x 22 PEOPLE = 220 CFM  
 377 CFM

CLASSROOM #250 IS SERVED BY RTU-4 WITH 400 CFM OUTSIDE AIR PROVIDED

**CLASSROOM #300:** 759 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.18 CFM/SQ. FT. x 759 SQ. FT. = 137 CFM  
 10 CFM/PERSON x 19 PEOPLE = 190 CFM  
 327 CFM

CLASSROOM #300 IS SERVED BY RTU-5 WITH 350 CFM OUTSIDE AIR PROVIDED

**CLASSROOM #350:** 715 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.18 CFM/SQ. FT. x 715 SQ. FT. = 129 CFM  
 10 CFM/PERSON x 18 PEOPLE = 180 CFM  
 309 CFM

CLASSROOM #350 IS SERVED BY RTU-6 WITH 350 CFM OUTSIDE AIR PROVIDED

**CLASSROOM #400:** 831 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.18 CFM/SQ. FT. x 831 SQ. FT. = 150 CFM  
 10 CFM/PERSON x 22 PEOPLE = 220 CFM  
 370 CFM

CLASSROOM #400 IS SERVED BY RTU-7 WITH 400 CFM OUTSIDE AIR PROVIDED

**CLASSROOM #450:** 784 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.18 CFM/SQ. FT. x 784 SQ. FT. = 142 CFM  
 10 CFM/PERSON x 20 PEOPLE = 200 CFM  
 342 CFM

CLASSROOM #450 IS SERVED BY RTU-8 WITH 350 CFM OUTSIDE AIR PROVIDED

**CLASSROOM #500:** 747 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.12 CFM/SQ. FT. x 747 SQ. FT. = 90 CFM  
 10 CFM/PERSON x 19 PEOPLE = 190 CFM  
 280 CFM

CLASSROOM #500 IS SERVED BY RTU-9 WITH 300 CFM OUTSIDE AIR PROVIDED

**CLASSROOM #550:** 799 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.12 CFM/SQ. FT. x 799 SQ. FT. = 96 CFM  
 10 CFM/PERSON x 20 PEOPLE = 200 CFM  
 296 CFM

CLASSROOM #500 IS SERVED BY RTU-10 WITH 300 CFM OUTSIDE AIR PROVIDED

**ACTIVITY ROOM #600:** 2042 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.12 CFM/SQ. FT. x 2042 SQ. FT. = 245 CFM  
 10 CFM/PERSON x 51 PEOPLE = 510 CFM  
 755 CFM

CLASSROOM #500 IS SERVED BY RTU-11 & 12 WITH 800 CFM OUTSIDE AIR PROVIDED

**LUNCH ROOM #08:** 800 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.18 CFM/SQ. FT. x 800 SQ. FT. = 144 CFM  
 7.5 CFM/PERSON x 53 PEOPLE = 398 CFM

**KITCHEN #05:** 200 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.12 CFM/SQ. FT. x 200 SQ. FT. = 24 CFM  
 7.5 CFM/PERSON x 4 PEOPLE = 30 CFM  
 596 CFM

CLASSROOM #500 IS SERVED BY RTU-14 WITH 600 CFM OUTSIDE AIR PROVIDED

**LEARNING #21:** 300 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.12 CFM/SQ. FT. x 300 SQ. FT. = 36 CFM  
 10 CFM/PERSON x 10 PEOPLE = 100 CFM

**CORRIDORS:** 600 SQ. FT.  
 OUTSIDE AIR REQUIRED: 0.06 CFM/SQ. FT. x 600 SQ. FT. = 36 CFM  
 0 CFM/PERSON x - PEOPLE = 0 CFM  
 172 CFM

CLASSROOM #500 IS SERVED BY RTU-15 WITH 200 CFM OUTSIDE AIR PROVIDED

## MECHANICAL NOTES:

- VERIFY ALL DIMENSIONS AND CONDITIONS AT JOB SITE AND FROM ARCHITECTURAL PLANS.
- CONTRACTOR AND SUB-CONTRACTOR SHALL PAY FOR ALL PERMITS AND CHARGES REQUIRED AND COMPLY WITH ALL GOVERNING CODES AND ORDINANCES.
- VISITING THE SITE: EACH BIDDER SHALL VISIT THE SITE OF THE PROPOSED WORK AND SHALL FULLY INFORM HIMSELF REGARDING THE FACILITIES. NO ADDITIONAL COMPENSATION WILL BE ALLOWED FOR WORK OR MATERIALS OMITTED FROM BIDDER'S CONTRACT PROPOSAL DUE TO HIS FAILURE TO SO INFORM HIMSELF BY SUCH INVESTIGATION.
- CONTRACTOR SHALL COORDINATE WITH THE ARCHITECT AND STRUCTURE ENGINEER PRIOR TO THE PLACEMENT OF EQUIPMENT ON THE ROOF AND THE CUTTING OF THE ROOF OPENINGS.
- REFER TO REFLECTIVE CEILING PLAN FOR THE EXACT LOCATIONS OF ALL CEILING AIR DEVICES.
- FURNISH AND INSTALL COMPLETE AND OPERATIONAL MECHANICAL SYSTEMS AS SHOWN ON PLANS AND SPECIFIED HEREIN.
- DUCKWORK SHALL BE AS FOLLOWS:
  - GALVANIZED SHEETMETAL CONSTRUCTED AND INSTALLED ACCORDING TO SMACNA STANDARD FOR LOW VELOCITY DUCTWORK.
  - FURNISH AND INSTALL AIR SCOOPS, EXTRACTORS, SPIN-IN FITTINGS WITH VOLUME DAMPERS AND SPLIT DAMPERS WITH OPERATORS AND LOCKING QUADRANTS AT ALL SPLITS, BRANCH CONNECTIONS AND REGISTER OR DIFFUSER CONNECTIONS TO DUCKWORK AND AS OTHERWISE INDICATED ON PLANS.
  - INSULATE ALL GALVANIZED SHEETMETAL SUPPLY, RETURN AIR DUCTS WITH 1.5" (R-6) OR 2" (R-8) DUCT LINER.
  - DIMENSIONS SHOWN ON PLANS SHALL BE FREE AIR FLOW AREA.
  - FLEXIBLE DUCT SHALL BE INSULATED AND MAX. LENGTH 6'-0" WHERE LONGER RUNS ARE REQUIRED COMBINE FLEX. DUCT WITH RIGID ROUND DUCT (INSULATED).
  - SEAL ALL TRANSVERSE JOINTS, SEAMS AND FITTINGS WITH FOSTER "32-50" WATER BASE HIGH VELOCITY DUCT SEALANT IN ACCORDANCE WITH SMACNA STANDARD.
- CONDENSATE LINES SHALL BE COPPER.
- PROVIDE COMPLETE HVAC CONTROL SYSTEMS INCLUDING ELECTRONIC PROGRAMMABLE THERMOSTAT WITH TAMPER-PROOF LOCKING COVER, CONTROL WIRING CONDUITS, INTERLOCK WIRING AND CONTROL DEVICES. PROGRAMMABLE THERMOSTATS SHALL COMPLY WITH IECC 803.2.3.1 & 803.3.3.2 FOR SET BACK, TIME OF DAY, START/STOP, MANUAL OVERRIDE, AND MINIMUM 5° FDEADBAND CONTROL.
- SUPPLY AIR DIFFUSER SHALL BE TITUS MODEL TDC, UNLESS OTHERWISE NOTED, 24"x24" FACE, ROUND OR SQUARE NECK WITH VOLUME DAMPER.
- CEILING RETURN AIR GRILLES SHALL BE TITUS MODEL PAR OR EQUAL.
- SUPPLY AIR REGISTERS SHALL BE TITUS MODEL 272FL OR EQUAL WITH OPPOSED BALDE DAMPERS.
- CONTRACTOR SHALL INSTALL ALL MECHANICAL EQUIPMENT IN ACCORDANCE WITH MANUFACTURER'S RECOMMENDATIONS.
- CONTRACTOR SHALL PROVIDE U.L. LISTED FIRE DAMPERS FOR AIR DISTRIBUTION SYSTEMS AT FIRE RATED WALLS AND CEILING PENETRATIONS IN ACCORDANCE WITH LOCAL CODES.
- BALANCE AIR DISTRIBUTION SYSTEMS PER AABC STANDARDS. CONTRACTOR SHALL SUBMIT FINAL BALANCING REPORT SIGNED BY AABC CERTIFIED ENGINEER.
- FURNISH AND INSTALL KITCHEN HOOD VENTILATION SYSTEM PER NFPA 96. HOOD EXHAUST DUCTS SHALL BE CONSTRUCTED OF 18 GAGE TYPE 316 STAINLESS STEEL WITH WELDED SEAMS & JOINTS.
- BALANCE KITCHEN HOOD VENTILATION SYSTEMS PER AABC OR NEBB STANDARDS.
- KITCHEN HOOD SHALL BE UL LISTED WITH ANSUL R-102 FIRE SUPPRESSION SYSTEM AND MECHANICAL GAS VALVE.
- PERFERRED MOUNTING HEIGHT FOR REMOTE TEMPERATURE SENSORS TO BE AT 72" ABOVE FINISH FLOOR. IF THE REMOTE TEMPERATURE SENSOR LOCATION CONFLICTS WITH OTHER TRADES, CONSULT PROJECT ARCHITECT FOR THE FINAL LOCATION. FIELD VERIFY.

## PACKAGED ROOFTOP UNIT SCHEDULE

MARK	RTU-1	RTU-2	RTU-3	RTU-4	RTU-5	RTU-6	RTU-7	RTU-8	RTU-9	RTU-10	RTU-11	RTU-12	RTU-13	RTU-14	RTU-15	
E V A P O R A T O R	DISCHARGE (HORIZONTAL OR VERTICAL)	VERTICAL	VERTICAL	VERTICAL	VERTICAL	VERTICAL	VERTICAL	VERTICAL	VERTICAL	VERTICAL	VERTICAL	VERTICAL	VERTICAL	VERTICAL	VERTICAL	
	SUPPLY AIRFLOW (CFM)	1,080	1,080	1,080	1,440	1,440	1,440	1,440	1,440	1,800	1,800	1,800	1,440	1,800	1,440	
	OUTSIDE AIRFLOW (CFM)	240	240	240	400	350	350	400	350	300	300	400	400	200	600	200
	EXTERNAL STATIC PRESSURE (IN. W.G.)	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8	0.8
	SUPPLY FAN MOTOR SIZE (HP)	1.2	1.2	1.2	1.7	1.7	1.7	1.7	1.7	1.7	2.4	2.4	2.4	1.7	2.4	1.7
	ENTERING AIR TEMP. - DB/WB (F)	80/67	80/67	80/67	80/67	80/67	80/67	80/67	80/67	80/67	80/67	80/67	80/67	80/67	80/67	80/67
C O N D E N S I N G	MIN. TOTAL CAPACITY (BTUH)*	34,800	34,800	34,800	46,600	46,600	46,600	46,600	46,600	60,500	60,500	60,500	46,600	60,500	46,600	
	MIN. SENSIBLE CAPACITY (BTUH)*	24,600	24,600	24,600	32,300	32,300	32,300	32,300	32,300	44,500	44,500	44,500	32,300	44,500	32,300	
	MINIMUM STAGES OF COOLING	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
	MAXIMUM TOTAL POWER INPUT AT RATED CAPACITY (KW)	2.9	2.9	2.9	3.7	3.7	3.7	3.7	3.7	4.6	4.6	4.6	3.7	4.6	3.7	
	MINIMUM SEER/ EER	13.0/-	13.0/-	13.0/-	13.0/-	13.0/-	13.0/-	13.0/-	13.0/-	13.0/-	13.0/-	13.0/-	13.0/-	13.0/-	13.0/-	
	DESIGN AMBIENT AIR TEMP. (F)	95	95	95	95	95	95	95	95	95	95	95	95	95	95	
H E A T I N G	TYPE	GAS	GAS	GAS	GAS	GAS	GAS	GAS	GAS	GAS	GAS	GAS	GAS	GAS	GAS	
	MIN. HEATING CAPACITY (MBH)	56	56	56	56	56	56	56	56	56	56	56	56	56	56	
	MAX. INPUT (MBH)	72	72	72	72	72	72	72	72	72	72	72	72	72	72	
	MIN. NUMBER OF STAGES	1	1	1	1	1	1	1	1	1	1	1	1	1	1	
MCA / MOCP (AMPS)	10.2 / 15	10.2 / 15	10.2 / 15	10.7 / 15	10.7 / 15	10.7 / 15	10.7 / 15	10.7 / 15	10.7 / 15	13 / 20	13 / 20	13 / 20	10.7 / 15	13 / 20	10.7 / 15	
VOLTS / PHASE	460/3	460/3	460/3	460/3	460/3	460/3	460/3	460/3	460/3	460/3	460/3	460/3	460/3	460/3	460/3	
APPROX. WEIGHT (LBS)	700	700	700	800	800	800	800	800	800	800	800	800	800	800	800	
BASIS OF DESIGN	CARRIER	CARRIER	CARRIER	CARRIER	CARRIER	CARRIER	CARRIER	CARRIER	CARRIER	CARRIER	CARRIER	CARRIER	CARRIER	CARRIER	CARRIER	
MODEL	48TC A04	48TC A04	48TC A04	48TC A05	48TC A05	48TC A05	48TC A05	48TC A05	48TC A05	48TC A06	48TC A06	48TC A06	48TC A05	48TC A06	48TC A05	
NOTES	1	1	1	1	1	1	1	1	1	2	2	2	1	2	1	
1- PROVIDE UNIT WITH BELT DRIVE BLOWER, 14" HIGH ROOF CURB, PROGRAMMABLE THERMOSTAT WITH REMOTE TEMPERATURE SENSOR AND LOW-AMBIENT KIT.																
2- PROVIDE UNIT WITH BELT DRIVE BLOWER, 14" HIGH ROOF CURB, PROGRAMMABLE THERMOSTAT WITH REMOTE TEMPERATURE SENSOR, LOW-AMBIENT KIT AND DRY-BULB ECONOMIZER.																
* INCLUDES DUCTWORK, AIR DEVICES, AND FILTER LOADING; DOES NOT INCLUDE COIL, CASING OR OTHER UNIT LOSSES.																
** AT SCHEDULED AMBIENT AIR TEMPERATURE.																

## KITCHEN AIR BALANCE SCHEDULE

UNIT	MAKE-UP AIR	EXHAUST AIR
RTU-14	600	----
EF-C	----	1000
MAKE-UP AIR FROM CORRIDOR	400	----
TOTAL	1,000	1,000

## UNIT HEATER SCHEDULE

PLAN DESIGNATION	TYPE	SERVICE	INPUT(KW)	VOLTS / PHASE	BASIS OF DESIGN	MODEL	NOTES
UH-1	ELECTRIC	SPRINKLER ROOM	3.0	277/1	Q-MARK	MUH0371	1
UH-2, 3, 4, 5	ELECTRIC	CEILING PLENUM FREEZE PROTECTION	5.0	277/1	Q-MARK	MUH0571	1
NOTES:							
1. PROVIDE ELECTRIC UNIT HEATERS WITH MOUNTING KIT AND UNIT-MOUNT THERMOSTAT.							

## FAN SCHEDULE

MARK	EF-A	EF-B	EF-C	EF-D	EF-E
SERVICE	TOILET EXHAUST	TOILET EXHAUST	KITCHEN HOOD EXHAUST	ELECTRICAL ROOM EXHAUST	TOILET EXHAUST
UNIT TYPE	CENTRIFUGAL	CENTRIFUGAL	CENTRIFUGAL	CENTRIFUGAL	CENTRIFUGAL
DRIVE TYPE	DIRECT	DIRECT	BELT	DIRECT	DIRECT
TOTAL AIRFLOW (CFM)	60	120	1,000	400	50
EXTERNAL STATIC PRESSURE (IN. W.G.)	0.25	0.125	1.25	0.125	0.25
MAXIMUM ACCEPTABLE SONES	1.1	1.4	-	4.1	1.1
MOTOR SIZE (HP)	29-WATT	53-WATT	1/2	121-WATT	29-WATT
VOLTS / PHASE	120/1	120/1	120/1	120/1	120/1
BASIS OF DESIGN	GREENHECK	GREENHECK	COOK	GREENHECK	GREENHECK
MODEL	SP-A90	SP-A125	120-CPS-A	SP-A410	SP-A90
ACCESSORIES	DS.BD.SC.RCP	DS.BD.SC.RCP	AD.IOF.DS.GT.BG	DS.BD.SC.RCP	DS.BD.SC.RCP
NOTES	1	1	3	2	1
NOTES	1. CONTROLLED BY WALL-MOUNT SWITCH.			ACCESSORIES:	
	2. FAN SHALL BE CONTROLLED BY WALL-MOUNT THERMOSTAT.			BD-BACKDRAFT DAMPER; AD-ACCESS DOOR	
	3. FAN SHALL BE UL LISTED FOR KITCHEN HOOD EXHAUST.			DS-DISCONNECT SWITCH; RCP-ROOF CAP	
				IOF-INLET/OUTLET FLANGE; BG-BELT GUARD	
				GT-GREASE TROUGH WITH DRAIN CONNECTION	
* EXTERNAL STATIC PRESSURE CONSISTS OF DUCTWORK, AIR DEVICES, AND FILTERS.				SC-SPEED CONTROLLER; WCP-WALL CAP	

## REVISIONS AND ISSUANCE

NO.	DATE	DESCRIPTION
08/13/2018	PRICING	
08/31/2018	ISSUE FOR PERMIT	

**IVY KIDS EARLY LEARNING CENTER**  
**4434 CR 94**  
**Manvel, Tx 77578**

MEP Consultants  
 BLK Engineering & Consulting Co.  
 3423 Spring Arbor Ln.  
 Sugar Land, TX 77479  
 (t) 832 563 3127  
 TBPE Firm #12672



08-31-2018

DRAWING TITLE

**MECHANICAL SCHEDULES**

DRAWN BY: FK  
 CHECKED BY: CK

DATE: 03/30/2017  
 JOB NO.: sedona lakes

DRAWING NO.: **M-2.0**